



Ref. Certif. No.

FR_724851

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Lithium-Ion Battery
Recharge Li-ion Energy Storage System

Name and address of the applicant

BSL NEW ENERGY TECHNOLOGY CO., LTD
8F, Building D-2-3, 1F, Building D-2-3, 8F, Building D-2-2, No. 6,
Xingyuan North Road, Starting Area, China-Korea Huizhou
Industrial Park, Zhongkai District
Huizhou City, Guangdong - CHINA

Name and address of the manufacturer

BSL NEW ENERGY TECHNOLOGY CO., LTD
8F, Building D-2-3, 1F, Building D-2-3, 8F, Building D-2-2, No. 6,
Xingyuan North Road, Starting Area, China-Korea Huizhou
Industrial Park, Zhongkai District
Huizhou City, Guangdong - CHINA

Name and address of the factory

BSL NEW ENERGY TECHNOLOGY CO., LTD
8F, Building D-2-3, 1F, Building D-2-3, 8F, Building D-2-2, No. 6,
Xingyuan North Road, Starting Area, China-Korea Huizhou
Industrial Park, Zhongkai District
Huizhou City, Guangdong - CHINA

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62619:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

CXBE-ESH-P26030569


This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 20/07/2026

Signature: 
Certification Officer



ANNEX

References, ratings and main characteristics:


Model	Nominal voltage (V)	Rated capacity (Ah)	Nominal Energy (kWh)
ESS-BATT R25	256V	102Ah	26.1kWh
ESS-BATT R30	307.2V	102Ah	31.32kWh
ESS-BATT R35	358.4V	102Ah	36.54kWh
ESS-BATT R40	409.6V	102Ah	41.76kWh
ESS-BATT R45	460.8V	102Ah	46.98kWh
ESS-BATT R50	512V	102Ah	52.2kWh
ESS-BATT R55	563.2V	102Ah	57.42kWh
ESS-BATT R60	614.4V	102Ah	62.64kWh
ESS-BATT R65	665.6V	102Ah	67.86kWh
ESS-BATT R70	716.8V	102Ah	73.08kWh
ESS-BATT R75	768V	102Ah	78.3kWh



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



Signature: **Julien GAUTHIER**
Certification Officer

Date: 20/07/2026