



Ref. Certif. No.

FR_720641/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Lithium-Ion Battery

Lithium-ion Battery Energy Storage Cabinet

Name and address of the applicant

BSL NEW ENERGY TECHNOLOGY CO., LTD

8F, Building D-2-3, 1F, Building D-2-3, 8F, Building D-2-2, No. 6, Xingyuan North Road, Starting Area, China-Korea Huizhou Industrial Park, Zhongkai District, Huizhou City, Guangdong - China

Name and address of the manufacturer

BSL NEW ENERGY TECHNOLOGY CO., LTD

8F, Building D-2-3, 1F, Building D-2-3, 8F, Building D-2-2, No. 6, Xingyuan North Road, Starting Area, China-Korea Huizhou Industrial Park, Zhongkai District, Huizhou City, Guangdong - China

Name and address of the factory

BSL NEW ENERGY TECHNOLOGY CO., LTD

8F, Building D-2-3, 1F, Building D-2-3, 8F, Building D-2-2, No. 6, Xingyuan North Road, Starting Area, China-Korea Huizhou Industrial Park, Zhongkai District, Huizhou City, Guangdong - China

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_720641 dated 13/12/2024.
Update the list of product references

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62619:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

CNDQ-ESH-P24111058,
CNDQ-ESH-P24111058-A1


This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 13/03/2025

Signature: **Jérôme REYSSON**
Certification Officer



ANNEX

Model	Nominal voltage(V)	Rated capacity (Ah)	Rated Power (kWh)
ESS-BATT 241C	768	314	241
ESS-BATT 225C	716,8	314	225
ESS-BATT 208C	665,6	314	208
ESS-BATT 192C	614,4	314	192
ESS-BATT 176C	563,2	314	176
ESS-BATT 160C	512	314	160



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 13/03/2025

Signature: Jérôme REYSSON
Certification Officer

